



298331



"Szela, Christopher F "
<CFSzela@integrysgroup.com
>

To

07/03/2007 01:21 PM

Subject Crawford Station - Parcel (O)- ComEd Towers

The easement area of Parcel "O" where ComEd is installing the new (south) tower is on top of an old purifier box.

Based on the test trenching performed by the ComEd contractor, it appears that the purifier was filled with brick, rubble and debris; there were no odors or visual impacts.

I spoke with Tim Prendiville (USEPA) about the test trenching field observations by Burns & McDonnell on July 3, 2007. The boring location already drilled through the bottom of the purifier box (last week). As such, and based on the field observations in conjunction with the previous soil boring 15 ft away from the caisson (B-6), Tim felt that ComEd could continue with their caisson installation (next week).

I will send the borings/soil samples that have been done in this area in addition to the ComEd soil borings on their property (Parcel "Q"), along with the test trenching to Tim Prendiville next week.

Christopher F. Szela, P.E.

Project Manager

312-240-4648 phone

312-240-4725 fax

CFSzela@integrysgroup.com

The information transmitted is intended only for the person or entity to which it is addressed and may contain confidential and/or privileged material. Any review, retransmission, dissemination or other use of, or taking of any action in reliance upon, this information by persons or entities other than the intended recipient is prohibited. If you received this in error, please contact the sender and delete the material from any computer.